



NOTES:

1. A MINIMUM OF 10 FT CLEARANCE SHALL BE REQUIRED BETWEEN BOTTOM OF "DRIP LOOP" AND FINAL GRADE.
2. CUSTOMER TO LEAVE 18" - 24" OF SERVICE ENTRANCE CONDUCTORS EXTENDED FROM WEATHERHEAD AND IDENTIFIED PER NEC REQUIREMENTS.



200 N. ROANE STREET
HARRIMAN, TN 37748

ASSEMBLY GUIDE
RESIDENTIAL SERVICE MAST
(120 VOLTS TO GROUND)

SCALE: NONE